

## **ELECTRICAL REQUIREMENTS FOR ALL 120V 20-AMP COPIERS**

All SHARP 120 volt 20-AMP copiers above 50 C.P.M. require that only a 20 ampere dedicated electrical power source be used. Since these models are equipped with a 20 ampere power cord, a 20 ampere -receptacle on a dedicated 20 ampere line is required for installation of these models.

Customer locations must be equipped with a 20 ampere power receptacle (Nema 5-20R, 20A, 125V) prior to delivery of the machine. The installation of the wall outlet must be performed by a licensed electrician and conform to local, state, and national electrical codes.

Any alterations to the power cord or power receptacle, including pigtails or adapters, can be extremely dangerous and could lead to electrical fires.

All service warranties will be null and void until such time proper power is available to appropriately power the SHARP/RICOH copiers.


It is also required that a CBE authorized surge suppressor be used on all SHARP copiers. A surge suppressor will protect your machine from any voltage drops or spikes that occur on your power line, thus eliminating the risk of erroneous codes, logic errors, or printed circuit board damage.

Is proper power available next to the machine? YES\_\_\_\_ NO\_\_\_\_


If NO, expected date of 20-AMPERE line DATE \_\_\_ / \_\_\_ / \_\_\_\_\_

Customer Signature \_\_\_\_\_

Title \_\_\_\_\_



**NEMA 5-20R**



**NEMA 5-20P**